

NOTES:

- 1. The ramp shall have a 12-inch wide border with 1/4-inch grooves approximately 3/4-inch on center at the level surface of the sidewalk. The finished surface of the ramp including flared sides shall be firm, slip-resistant, and shall be of contrasting finish from that of the adjacent sidewalk.
- 2. Curb ramps that have a ramp slope flatter than 6.67 % shall have a detectable warning surface that extends the full width of the ramp and 24" minimum length. Detectable warning surfaces, shall be constructed at the contractors option either cast-in-place or the stamped method.

CITY OF MILPITAS, ENGINEERING DIVISION				STANDARD DRAWING	
REVISION	DATE	DESIGNED:	MIDBLOCK RAMP	NO. 424	
\wedge		DRAWN: JV	MIDDLOCK RAMP	100.424	
		CHECKED: MK	RESIDENTIAL/INDUSTRIAL	ORIGINAL: 9/04/96 DATE	
		APPROVEI PUBLIC	WORKS DIRECTOR / CITY ENGINEER DATE: 11/9/00	SHEET 1 OF 1	